



**ADDENDUM #1  
for  
NOTICE TO BIDDERS  
HHW BUILDING FLOOR OVERLAY AND CONTAINMENT REPAIR,  
HUMBOLDT WASTE MANAGEMENT AUTHORITY  
Bid Date: Friday, October 12, 2018**

October 5, 2018

To All Bidders:

This is an Addendum to the HHW Building Floor Overlay and Containment Repair (Bid Documents) currently in bidding with a bid date of October 12, 2018. The following questions were received to the Humboldt Waste Management Authority (HWMA) office prior to the deadline of 4:00 p.m. (PST) on October 3, 2018. Please reference this Addendum in your submitted bid proposal.

The text below summarizes the request for information, and response. Italicized portions indicate the questions received with the responses following:

- 1. In reference to the Specification package, the primary contractor of the work is required to have a California Class A (General Engineering), or Class C license(s) required to perform the work. Will a Class B or C-8 license be acceptable?*

Response: The contracts documents and license requirements are intended to include the appropriate Class C type licenses required to perform the work. A California contractor C-8 license is for concrete and would be acceptable for this project.

- 2. In reference to the Drawing package, C2.0 Sheet note 5. "Apply floor overlay over existing asphalt area. Floor overlay to be 1-inch thick." Will this have areas 1" thick? What will be the minimum acceptable thickness?*

Response: The minimum thickness indicated on sheet C2.0 was based on general product minimum specifications and associated warranties. Specific products shown in the bid documents are noted with lower minimum thickness tolerances for performance, however the minimum for project construction purposes is ½" thick **or** the minimum product tolerance, whichever is greater.